



SECTION 08330 [08 33 00]

ROLLING STEEL DOORS

Display hidden notes to specifier. (Don't know how? [Click Here](#))
Copyright 2013 – 2021 ARCAT, Inc All rights reserved

**** NOTE TO SPECIFIER ** Wayne Dalton; Rolling steel door products.**

This section is based on the products of Wayne Dalton, which is located at:
2501 S. State Highway 121 Business, Suite 200
Lewisville, TX 75067
Phone: (800) 827-3667
Web Site: www.wayne-dalton.com
Email: info@wayne-dalton.com.
[click Here] for additional information.

Wayne Dalton Rolling Doors have a long history of excellence in the design and construction of doors that have met and often exceeded the needs and expectations of even the most critical projects.

With numerous innovations created and experience acquired over the years, Wayne Dalton continues to lead all other manufacturers with both standard and custom-made doors from a variety of materials and colors to meet almost any need.

So whether it's the over-sized Model 800 rolling doors, protective FireStar rolling fire doors, or secure rolling grilles, you can feel confident that with Wayne Dalton's many years of knowledge and experience, you will get the best possible solution for your building application needs.

PART 1 GENERAL

1.1 SECTION INCLUDES

**** NOTE TO SPECIFIER ** Delete items below not required for project.**

- A. Rolling steel doors.
- B. Rolling steel springless high cycle doors.
- C. Rolling steel advanced performance service doors.
- D. Rolling steel fire doors.
- E. Overhead Coiling Security Shutters.

1.2 RELATED SECTIONS

**** NOTE TO SPECIFIER ** Delete any sections below not relevant to this project; add others as required.**

- A. Section 05500 - Metal Fabrications: Support framing and framed opening.
- B. Section 06200 - Finish Carpentry: Wood jamb and head trim.
- C. Section 08710 - Door Hardware: Product Requirements for cylinder core and keys.
- D. Section 09900 - Painting: Field applied finish.
- E. Section 16130 - Raceway and Boxes: Conduit from electric circuit to door operator and from door operator to control station.
- F. Section 16150 - Wiring Connections: Power to disconnect.

1.3 REFERENCES

**** NOTE TO SPECIFIER ** Delete references from the list below that are not actually required by the text of the edited section.**

- A. ANSI/DASMA 108 - American National Standards Institute Standard Method For Testing Sectional Garage Doors And Rolling Doors: Determination Of Structural Performance Under Uniform Static Air Pressure Difference.
- B. ANSI/DASMA 203 - American National Standards Institute Specifications for non-rated fire rolling doors published by Door & Access Systems Manufacturers Association International.
- C. ASTM A 123 - Zinc hot-dipped galvanized] coatings on iron and steel products.
- D. ASTM A 229 - Steel wire, oil-tempered for mechanical springs.
- E. ASTM A 653 - Steel sheet, zinc-coated galvanized by the hot-dipped process, commercial quality.
- F. ASTM E 330 - Structural performance of exterior windows, curtain walls, and doors by uniform static air pressure difference.
- G. ASTM E 413 - Classification for Rating Sound Insulation

1.4 SUBMITTALS

- A. Submit under provisions of Section 01300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Include detailed plans, elevations, details of framing members, anchoring methods, required clearances, hardware, and accessories. Include relationship with adjacent construction.

**** NOTE TO SPECIFIER ** Delete the following paragraphs if LEED is not applicable.**

- D. LEED Submittals: Provide documentation of how the requirements of Credit will be met:
 - 1. List of proposed materials with recycled content. Indicate post-consumer recycled content and pre-consumer recycled content for each product having recycled content.
 - 2. Product data and certification letter indicating percentages by weight of post-consumer and pre-consumer recycled content for products having recycled content.

**** NOTE TO SPECIFIER ** Delete selection samples if colors have already been selected.**

- E. Selection Samples: For each finish product specified, two complete sets of color chips representing manufacturer's full range of available colors and patterns.
- F. Verification Samples: For each finish product specified, two samples, minimum size 6 inches (150 mm) long, representing actual product, color, and patterns.
- G. Manufacturer's Certificates: Certify products meet or exceed specified requirements.
- H. Closeout Submittals: Provide manufacturer's maintenance instructions that include recommendations for periodic checking, adjustment and lubrication of components.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in performing Work of this section with a minimum of five years experience in the fabrication and installation of security closures.
- B. Installer Qualifications: Installer Qualifications: Company specializing in performing Work of this section with minimum three years and an authorized Wayne Dalton installer.

**** NOTE TO SPECIFIER ** Include a mock-up if the project size and/or quality warrant taking such a precaution. The following is one example of how a mock-up on a large project might be specified. When deciding on the extent of the mock-up, consider all the major different types of work on the project.**

- C. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
 - 1. Finish areas designated by Architect.
 - 2. Do not proceed with remaining work until workmanship, color, and sheen are approved by Architect.
 - 3. Refinish mock-up area as required to produce acceptable work.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Store products in manufacturer's unopened packaging with seals and labels intact until ready for installation.
- B. Store materials off the ground in a dry, warm, ventilated weathertight location.

1.7 SEQUENCING

- A. Ensure that locating templates and other information required for installation of products of this section are furnished to affected trades in time to prevent interruption of construction progress.
- B. Ensure that products of this section are supplied to affected trades in time to prevent interruption of construction progress.

1.8 PROJECT CONDITIONS

- A. Maintain environmental conditions (temperature, humidity, and ventilation) within limits recommended by manufacturer for optimum results. Do not install products under environmental conditions outside manufacturer's absolute limits.

1.9 WARRANTY

**** NOTE TO SPECIFIER ** Include the following warranty paragraph for Models 900, 800, 800C, 700 or 700C rolling service doors with Genie GCL-MH, MJ, J, H, or GH commercial door operators provided together as a System. Delete if not applicable.**

- A. Warranty: Manufacturer's limited door and operator system, except the counterbalance spring and finish, to be free from defects in materials and workmanship for 3 years or 20,000 cycles, whichever occurs first.

**** NOTE TO SPECIFIER ** Include the following warranty paragraph for Model 900, 926, 800, 800C, 700, and 700C rolling service doors and Model 523 shutters not provided as a system with operators. Delete if not applicable.**

- B. Warranty: Manufacturer's limited door system warranty for 2 years for all parts and components.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Wayne Dalton; 2501 S. State Highway 121 Business, Suite 200, Lewisville, TX 75067. ASD. Phone: (800) 827-3667; Web Site: www.wayne-dalton.com. Email: info@wayne-dalton.com.

**** NOTE TO SPECIFIER ** Delete one of the following two paragraphs; coordinate with requirements of Division 1 section on product options and substitutions.**

- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

**** NOTE TO SPECIFIER ** Select the doors required from the following paragraphs and delete those not required.**

2.2 ROLLING STEEL SERVICE DOORS

- A. Wayne Dalton Model 900 Rolling Service Doors:
 - 1. Description:
 - a. Maximum Width: 14 feet

- a. Maximum Height: 14 feet
- 2. Curtain: composed of interlocking roll-formed slats.
 - a. Slat Profiles/Material:

**** NOTE TO SPECIFIER ** Select the slat profile and material required from the following paragraphs and delete those not required.**

- 1) No. 2 Curved-faced single crown slat.
 - (a) 24-gauge steel.
 - (b) 22-gauge steel.
 - (c) 20-gauge steel.
 - (d) 22-gauge stainless steel.
 - (e) 20-gauge stainless steel.
 - (f) 18-gauge aluminum (mill finish).
- 2) No. 17 Flat-faced slat.
 - (a) 24-gauge steel.
 - (b) 22-gauge steel.
 - (c) 20-gauge steel.
 - (d) 22-gauge stainless steel.
 - (e) 20-gauge stainless steel.
- 3) Secur-Vent Perforated slat provides optimal security and ventilation. Slat consists of 1/16 inch diameter holes offering 41 percent open area over length of each slat. Available in No. 17 flat slat up to 14 feet wide by 12 feet high.

**** NOTE TO SPECIFIER ** Select the material required from the following paragraphs and delete the one not required.**

- (a) 22-gauge steel.
- (b) 22-gauge stainless steel.
- b. Ends of alternate slats fitted with metal endlocks/windlocks.
- 3. Bottom Bar: Consists of two equal angles, 0.12 inch minimum thickness, to stiffen curtain, with astragal. Angle shall be:

**** NOTE TO SPECIFIER ** Select the bottom bar material required from the following paragraphs and delete those not required. Steel is standard.**

- a. Steel.
- b. Stainless steel.
- c. Aluminum.
- 4. Guides:

**** NOTE TO SPECIFIER ** Select the Guide required from the following paragraphs and delete those not required.**

- a. Roll-formed steel channel bolted to wall.
- b. Roll-formed steel channel bolted to three structural angle guide angle assembly forming a slot to retain curtains in guides. Structural grade, three angle assembly fabricated of:

**** NOTE TO SPECIFIER ** Select the assembly material required from the following paragraphs and delete those not required. Steel is standard.**

- 1) Steel.
- 2) Stainless steel.
- 3) Aluminum.
- c. Provide with integral windlock bars and removable bottom bar stops.
- 5. Brackets: Design to enclose ends of coil and provide support for counterbalance pipe at each end. Fabricate of steel plates, with permanently sealed ball bearings. Thickness shall be:

**** NOTE TO SPECIFIER ** Select the thickness required from the following paragraphs and delete those not required. 3/16 inch is standard.**

- a. 3/16 inch minimum.
- b. 1/4 inch minimum.

6. Counterbalance: Curtain to be coiled on a pipe of sufficient size to carry door load with deflection not to exceed 0.033 inch per foot of door span. Curtain to be correctly balanced by helical springs, oil tempered torsion type. Cast iron barrel plugs will be used to anchor springs to tension shaft and pipe.
7. Hood: Hood to enclose curtain coil and counterbalance mechanism. Hood fabricated of sheet metal, flanged at top for attachment to header and flanged at bottom to provide longitudinal stiffness. Fabricate of:

**** NOTE TO SPECIFIER ** Select the hood material required from the following paragraphs and delete those not required. 24-gauge galvanized steel is standard.**

- a. Minimum 22-gauge B&S aluminum.
 - b. Minimum 24-gauge galvanized steel.
 - c. Minimum 24-gauge stainless steel.
8. Finish: Shop coat of rust inhibitive primer on non-galvanized surfaces and operating mechanisms. Guides and bracket plates will be coated with a flat black prime paint.

**** NOTE TO SPECIFIER ** Select the finish and color required from the following paragraphs and delete those not required. Note that white, beige, brown is only available as 24 or 22-gauge. Custom colors are available from 180 colors.**

- a. Galvanized Steel:
 - 1) Gray baked on primer.
 - 2) White baked on primer.
 - 3) Beige baked on primer.
 - 4) Brown baked on primer.
 - 5) Powdercoat finish as selected from manufacturer's RAL color selections.
 - 6) Powdercoat finish in custom color as selected.
 - b. Aluminum Finish:
 - 1) Mill finish.
 - 2) Clear anodized.
 - 3) Bronze anodized.
 - c. Stainless Steel finish.
 - 1) #4 finish.
9. Operation: Door will be operated by means of:

**** NOTE TO SPECIFIER ** Select the operation required from the following paragraphs and delete those not required.**

- a. Manual, lift-up.
 - b. Chain hoist.
 - c. Awning crank.
 - d. Wall crank box.
 - e. Motor operation.
 - f. Motor operation with electrical sensing edge attached to bottom bar to stop and reverse door when it contacts an object during the closing cycle.
 - g. Motor operation with pneumatic sensing edge attached to bottom bar to stop and reverse door when it contacts an object during the closing cycle.
10. Weatherstripping: Bottom astragal, optional surface guide weatherstrip, and internal hood baffle.
 11. Locking:

**** NOTE TO SPECIFIER ** Select the locking required from the following paragraphs and delete those not required. When specifying locks on electric-motor operated doors, electric interlocks should also be specified to prevent operation when lock bolts are engaged in the guides, to prevent damage to the curtain and/or operator. Interior slide bolts are standard on manual doors and optional on others.**

- a. Interior slide-bolts suitable for padlocks by others.
- b. Chain-hoist door provided with chain keepers suitable for padlocks by others.
- c. Electric-motor operation doors provided with lock through the operator gearing.
- d. Provide with cylinder locks.
- e. Provide with thumb turn.

**** NOTE TO SPECIFIER ** Insert the windload required in the following paragraph. Doors are available with a minimum windload of plus or minus 20 psf (design pressure) and a maximum windload of plus or minus 31 psf (design pressure).**

- 12. Windload: Windload minimum ____ psf per DASMA 108-2012 and as required by local codes.
- 13. Mounting:
 - a. Steel jambs.
 - b. Wood jambs.
 - c. Masonry jambs.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until substrates have been properly prepared.
- B. Examine conditions of substrates, supports, and other conditions under which this work is to be performed.
- C. If substrate preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install in accordance with manufacturer's instructions.
- B. Install door complete with necessary hardware, jamb and head mold strips, anchors, inserts, hangers, and equipment supports in accordance with final shop drawings, manufacturers instructions, and as specified herein.
- C. Fit, align and adjust rolling door assemblies level and plumb for smooth operation.
- D. Upon completion of final installation, lubricate, test and adjust doors to operate easily, free from warp, twist or distortion and fitting for entire perimeter.

3.4 ADJUSTING

- A. Test for proper operation and adjust as necessary to provide proper operation without binding or distortion.
- B. Adjust hardware and operating assemblies for smooth and noiseless operation.

3.5 CLEANING

- A. Clean curtain and components using non-abrasive materials and methods recommended by manufacturer.
- B. Remove labels and visible markings.
- C. Touch-up, repair or replace damaged products before Substantial Completion.

3.6 PROTECTION

- A. Protect installed products until completion of project.
- B. Touch-up, repair or replace damaged products before Substantial Completion.

3.7 SCHEDULES

**** NOTE TO SPECIFIER ** Retain Paragraph below if required to suit project requirements. Identify products by name on the Drawings or use this paragraph to define the location of each type of material to be used. The following are some examples of schedule references. Edit as required to suit project or delete and identify products on the Drawings.**

- A. :
 - 1.
 - 2.
 - 3.
- B. :
 - 1.
 - 2.
 - 3.

END OF SECTION